



CITY OF PORT ST. LUCIE

BUILDING DEPARTMENT / PLAN REVIEW DIVISION

SLAB – THICKENED EDGE FOOTING SIZES

General Notes:

1. 6"x6" 10/10 WWM or Fibermesh added concrete
2. 6 MIL Visqueen vapor barrier required on termite treated soil when next to living space or under habitable space.
3. Compaction test required when fill exceeds 18", 95% minimum compaction required.

SLAB/FOOTING USED

